



TYPICAL WALL SECTION
C.I.P. CONCRETE

GENERAL NOTES

- ① CAST-IN-PLACE PIT CONSTRUCTION SHALL BE IN ACCORDANCE WITH ODOT 499 AND 511. CONCRETE SHALL BE 499, CLASS "C" (600# CEMENT/CY). REINFORCING STEEL SHALL CONFORM TO ODOT 509 ($f_y+60\text{ksi.}$). DIMENSIONS ARE TO TOD CENTERS UNLESS OTHERWISE NOTED. ALL REINFORCING STEEL SHALL HAVE 2" CLEARANCE UNLESS OTHERWISE NOTED. CHAMFER ALL EXPOSED EDGES $\frac{3}{4}$ ".
- ② CONCRETE BRICK OR BLOCK SHALL CONFORM TO ODOT 704.02 OR 704.03 RESPECTIVELY. CONSTRUCTION SHALL BE IN ACCORDANCE WITH ODOT 604. BLOCK TILES AND REINFORCEMENT SHALL BE INSTALLED IN ACCORDANCE WITH THE REQUIREMENTS OF "CONCRETE FOOTINGS AND CONCRETE MASONRY WALLS" AND "CONCRETE FOOTINGS AND REINFORCED CONCRETE MASONRY WALLS" AS PUBLISHED BY THE PORTLAND CEMENT ASSOCIATION.
- ③ BILCO DOOR SHALL BE MODEL JD 3AL DESIGNED FOR H-20 LOADING AND FURNISHED WITH RECESSED PADLOCK HASPS.



VILLAGE OF INDIAN HILL
DEPARTMENT OF WATER WORKS

APPROVED *J.P. Q.*
DATE November 2011

STANDARD METER PIT
FOR 3 IN. &
LARGER METERS

DRAWING NO.

WW-136